

| <b>UNDERGROUND (UG)</b>   |             |                 |                            |                     |                     |
|---------------------------|-------------|-----------------|----------------------------|---------------------|---------------------|
| Customer                  |             |                 | Line Extension             |                     | Service Connection  |
| Type                      | Load        | Service Voltage | Public Right-of-Way        | Private Property    | Private Property    |
| Residential               | Subdivision | Low             | 15 ft/lot <sup>2</sup>     | 150 ft <sup>3</sup> | NA <sup>4</sup>     |
|                           | Individual  |                 |                            |                     | NA <sup>4</sup>     |
| Commercial,<br>Industrial | < 75 kVA    | Low             | 3 ft/kW (C/I) <sup>2</sup> | 150 ft <sup>3</sup> | NA <sup>5</sup>     |
|                           | > 75 kVA    |                 |                            |                     | NA <sup>5</sup>     |
|                           | > 5000 kVA  | High            |                            |                     | NA <sup>6</sup>     |
| Agricultural              | < 75 kVA    | Low             | 1.5 ft/hp (Ag)             | 150 ft <sup>3</sup> | NA <sup>5</sup>     |
|                           | > 75 kVA    |                 |                            |                     | NA <sup>5</sup>     |
|                           | > 5000 kVA  | High            |                            |                     | NA <sup>6</sup>     |
| <b>OVERHEAD (OH)</b>      |             |                 |                            |                     |                     |
| Customer                  |             |                 | Line Extension             |                     | Service Connection  |
| Type                      | Load        | Service Voltage | Public Right-of-Way        | Private Property    | Private Property    |
| Residential               | Subdivision | Low             | 90 ft/lot                  | 150 ft              | UG Req <sup>d</sup> |
|                           | Individual  |                 |                            |                     | 200 ft              |
| Commercial,<br>Industrial | < 75 kVA    | Low             | 18 ft/kW                   | 150 ft              | 100 ft              |
|                           | > 75 kVA    |                 |                            |                     | UG Typ <sup>7</sup> |
|                           | > 5000 kVA  | High            |                            |                     | NA <sup>6</sup>     |
| Agricultural              | < 75 kVA    | Low             | 9 ft/hp                    | 150 ft              | 100 ft              |
|                           | > 75 kVA    |                 |                            |                     | UG Typ <sup>7</sup> |
|                           | > 5000 kVA  | High            |                            |                     | NA <sup>6</sup>     |

<sup>1</sup> Refer to the Electric Service Guides, District Standard Agreements, and Service Rules (2, 15, 16) for a complete description of the requirements, qualifications and limitations that apply to particular locations and installations.

<sup>2</sup> Where required only. Where optional, Customer provides substructure facilities.

<sup>3</sup> Cable only. Customer provides substructure facilities.

<sup>4</sup> Customer provides substructure facilities and cable. Actual limitation is based on engineering calculations for voltage drop.

<sup>5</sup> Customer owns and installs the conductors between the transformer and their main panel.

<sup>6</sup> Customer owns and installs the transformer. If UG, Customer also owns and installs the conduit system.

<sup>7</sup> 100 ft if OH.